

# Compliance Statement

No. 2025-055

## Unscreened Channel, Class E<sub>A</sub>

### Company

GIGAMEDIA  
CRT No. 4, 312 Rue des Hauts de Sainghin  
59811 Lesquin  
France

### Channel Identification (4 connector model)

#### Horizontal cable:

U/UTP Cat. 6A LSZH; Part no. C6AU4PFRxxx (xxx: packaging)

#### RJ45 connector for telecommunications outlet, consolidation point, and patch panel:

Unscreened Category 6A connector; Part no. TRJUC6A10G

#### Terminal cord, patch cord, equipment cord:

GIGAMEDIA S/FTP Cat.6A Patch cords, LSZH; Part no. CAT6ASxxMyy (xx:length, yy: colour)

#### Consolidation point cord:

U/UTP Cat. 6A LSZH; Part no. C6AU4PFRxxx  
(with plug PLUGC6SRIGx (x: colour) and jack TRJUC6A10G added)

#### RJ45 coupler:

Screened RJ45 coupler; Part no. 6210210GS00

#### Used with mounting fixtures:

Patch Panel: PANVC6A24BK

#### Generic cabling standards - Class E<sub>A</sub>/ Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

including all channel alien crosstalk parameters (PS ANEXT and PS AACR-F)

#### Technical report

12432617-04, DANAK-19/24756

#### EC Cabling product ID


7579

#### CS valid until


1 April 2026

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 3 February 2025



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department

